

Investor:	Město Konice	Vypracoval:	Ing. Radim Prouza
		Datum:	14-05-2021
Stavba:	Víceúčelová sportovní hala	Z.č.:	889-21
		A.č.:	889-2021

Teplota přívodu [°C]	45,0
-----------------------------	-------------

Poř. číslo okr.	Kód okruhu	q [W/ m ²]	TFm skut. [°C]	sigma [K]	Rozteč trubek [m]	Délka			Hmot. průtok [kg/hod]	Tlak. ztráta [Pa]	Rozdě- lovač [-]	Chybí [W]
						okruhu [m]	přívodu [m]	cizí [m]				
1	109/A	73,2	26,8	10,4	0,250	57,5	5,0	0,0	71,6	1594	1	---
2	110/A	31,1	18,1	10,0	0,250	29,0	2,0	3,8	52,9	476	1	---
3	112/A	81,4	27,5	5,0	0,200	38,0	6,0	0,0	155,5	4112	1	---
4	113/A	49,3	19,7	15,0	0,250	44,0	9,4	15,6	50,8	761	1	---
5	114/A	69,2	26,4	10,8	0,200	67,0	24,0	0,0	124,9	5878	1	---
6	115/A	69,2	26,4	10,0	0,200	67,0	17,2	0,0	130,0	5812	1	---