



## EXPLANATION OF TENDER DOCUMENTATION NO. 6

<b>Name of public contract:</b>	<b>S&amp;M Develop –Žipotín wind power plant – deliveries</b>
<b>Type of procurement procedure:</b>	Public contract not governed by Act No. 134/2016 Coll., on Public Procurement (hereinafter referred to only as the “APP”)
<b>Type of public contract:</b>	Deliveries
<b>Address of contracting authority’s profile:</b>	<a href="https://ezak.tendera.cz/profile_display_1129.html">https://ezak.tendera.cz/profile_display_1129.html</a>
<b>Identification of project:</b>	“S&M Develop –Žipotín wind power plant”, project registration number: CZ.01.3.09/0.0/0.0/19_302/0019938

<b>Name of contracting authority:</b>	<b>S&amp;M Develop s. r. o.</b>
<b>Registered office of contracting authority:</b>	Makovského náměstí 3147/2, Žabovřesky, 616 00 Brno
<b>Represented by:</b>	Martin Valter, Executive Director Jiří Svoboda, Executive Director
<b>Company ID No.:</b>	27534511
<b>VAT No.:</b>	CZ27534511

<b>Party representing the contracting authority:</b>	<b>TENDERA partners, s.r.o.</b>
<b>Registered office:</b>	Syrovice 424, 664 67
<b>Contact point:</b>	Česká 161/1, 602 00 Brno
<b>Company ID No.:</b>	08668477
<b>VAT No.:</b>	CZ08668477
<b>Contact person:</b>	Ing. Radek Hlaváček
<b>Telephone no.:</b>	+420 731 131 684
<b>E-mail:</b>	<a href="mailto:hlavacek@tendera.cz">hlavacek@tendera.cz</a>
<b>Data box identifier:</b>	he9gwrw

In accordance with the provisions of Art. 12 of the tender documentation, the contracting authority hereby provides explanation of the tender documentation for the public contract indicated above.

### I.

On 2 August 2021, a request for explanation of the tender documentation was delivered by e-mail to the party representing the contracting authority in accordance with Section 98(3) of the APP with the following wording:

### Question No. 1:

On behalf of XXX, we would like to ask for clarification of one issue. XXX is considering submitting a bid for the contract "S&M Develop - Žipotín Wind Power Plant" – Deliveries: Z2020-006144. Unfortunately, it is not possible to transport a wind power plant with a capacity of 4.2 MW to the place of delivery due to its size. XXX can offer a wind power plant with a capacity of 4.26 MW with smaller transport dimensions. However, this wind turbine has a somewhat higher capacity – 4,260 kW. Is it possible to increase the maximum capacity limit in the tender?

*The question has been anonymised.*

### The contracting authority states the following with regard to Question No. 1

Increasing the capacity of the wind power plant by 60 kW is possible. The Building Authority does not resolve any increase in capacity by a few percent (in this case by 1.5%) at all. The contracting authority agrees to an increase of the maximum capacity to 4.3 MW.

In view of the nature of the change, the contracting authority provides the following documents in their updated form:

- Appendix No. 2 to the tender documentation – Technical Specifications
- Appendix No. 2 to the tender documentation – Project Documentation (Part A, B and D 1.2.1).

Each tenderer is required to base its offer on or use these updated appendices. Failure to use these updated appendices will be regarded as failure to meet the tender conditions and such a tenderer will be excluded from the procurement procedure.

## II.

In relation to provision of this explanation of the tender documentation, the contracting authority has decided to extend the deadline for submission of offers and Article 10(3) and Article 11(1) of the tender documentation are replaced by the following wording:

### Article 10. **Method of submitting offers**

3. The offer shall be delivered to the address of the contact point for the party representing the contracting authority, i.e. to the address **TENDERA partners, s.r.o., Česká 161/1, 602 00 Brno, no later than 10:00 a.m. on 7 September 2021**. The tenderer may send their offer to the above-mentioned address by post or submit it in person on working days between the hours of 8:00 a.m. and 3:30 p.m. and on the last day of the deadline for submission of offers between the hours of 8:00 a.m. and 10:00 p.m.

### Article 11 **Opening of offers**

1. The committee appointed by the contracting authority shall open the envelopes with offers which have been delivered immediately on expiry of the deadline for submission of offers and check them at its **public meeting** held at the address of the contact point for the party representing the contracting authority at 10:00 a.m. on **7 September 2021**.

In Brno, on 6 August 2021

**On behalf of the contracting authority – S&M Develop s. r. o.:**

**Ing. Radek Hlaváček**

TENDERA partners, s.r.o.

Tender Consultant

Under power of attorney